



Report of Analysis

Mail to: Conrad Weiser Community Pool
161 South Freeman Street
PO Box 95
Robesonia PA 19551

Lab Number: **292673**
Date Reported: 06/10/2019

Analyte	Result	Pass/Fail	Maximum Contaminant Level	Analysis		Analyst	Method	Reporting Limit
				Date	Time			
292673-01 Sampled: 06/06/2019 11:19 Sampler: Dale Fry Source: PO1 Lap Pool Conrad Weiser Community Pool								
Bacteria, Total Coliform S/P	0 MPN/100mL	Pass	2 MPN/100mL	06/06/2019	15:14	ajy	SM9223	0

This sample was collected by a lab-authorized sampler.

292673-02 Sampled: 06/06/2019 11:19 Sampler: Dale Fry Source: PO1 Baby Pool Conrad Weiser Community Pool								
Bacteria, Total Coliform S/P	0 MPN/100mL	Pass	2 MPN/100mL	06/06/2019	15:14	ajy	SM9223	0

This sample was collected by a lab-authorized sampler.



The Maximum Contaminant Level (MCL) is the maximum permissible level of a contaminant in water per the SDWA. Some parameters have no established MCL. Pure-Test is certified #38-00338 by the Pennsylvania Department of Environmental Protection, #345 by the Maryland Department of the Environment.



Report Approved By:

Andrew T Heist, Lab Technician