



Report of Analysis

Mail to: Conrad Weiser Community Pool
161 South Freeman Street
PO Box 95
Robesonia PA 19551


Lab Number: **315744**
Date Reported: 07/06/2020

| Analyte | Result | Pass/Fail | Maximum Contaminant Level | Analysis | | Analyst | Method | Reporting Limit |
|--|-------------|-----------|---------------------------|------------|-------|---------|--------|-----------------|
| | | | | Date | Time | | | |
| 315744-01 Sampled: 07/01/2020 13:50 Sampler: Derek High Source: PO1 Lap Pool Conrad Weiser Community Pool | | | | | | | | |
| Bacteria, Total Coliform S/P | 0 MPN/100mL | Pass | 2 MPN/100mL | 07/01/2020 | 16:30 | ajy | SM9223 | 0 |
| This sample was collected by a lab-authorized sampler. | | | | | | | | |
| 315744-02 Sampled: 07/01/2020 13:50 Sampler: Derek High Source: PO2 Baby Pool Conrad Weiser Community Pool | | | | | | | | |
| Bacteria, Total Coliform S/P | 0 MPN/100mL | Pass | 2 MPN/100mL | 07/01/2020 | 16:30 | ajy | SM9223 | 0 |
| This sample was collected by a lab-authorized sampler. | | | | | | | | |



The Maximum Contaminant Level (MCL) is the maximum permissible level of a contaminant in water per the SDWA. Some parameters have no established MCL. Pure-Test is certified #38-00338 by the Pennsylvania Department of Environmental Protection, #345 by the Maryland Department of the Environment.



Report Approved By:

 Andrew T Heist, Lab Technician